

CB1	-	CIRCUIT BREAKER, 250A, 480V, 3PH, 35KAIC
CR1	-	CONTROL RELAY, 5A, 120V, 4-POLE
CR2	-	CONTROL RELAY, 5A, 120V, 4-POLE
CSXi	-	SOFT STARTER, CSXi SERIES, 200A, 380-600V, BYPASSED
ENCL	-	ENCLOSURE, WALL MOUNT, TYPE 12/4, 24"H x 20"W x 10"D
FU1-2	-	CONTROL FUSES (PRIMARY SIDE), TIME DELAY, 0.4A, 600V, 200KA CLASS CC
FU3	-	CONTROL FUSES (SECONDARY SIDE), TIME DELAY, 0.8A, 500V, 10KA
HTR	-	HEATER, 120V, 50W, RADIATED
TB1	-	CONTROL TERMINAL BLOCKS
TSTAT	-	THERMOSTAT, 0-60 DEG C, NCC STYLE
XF1	-	CONTROL TRANSFORMER, 75VA, 480V PRIMARY - 120V SECONDARY
LT1	-	PILOT LIGHT, 22MM, PTT, ILLUMINATED, 120V, RED LED
LT2	-	PILOT LIGHT, 22MM, PTT, ILLUMINATED, 120V, GREEN LED
LT3	-	PILOT LIGHT, 22MM, PTT, ILLUMINATED, 120V, AMBER LED
PB1	-	PUSHBUTTON, 22MM, FLUSH GREEN, W/ N.O. CONTACT
PB2	-	PUSHBUTTON, 22MM, RAISED RED, W/ N.C. CONTACT
SW1	-	SELECTOR SWITCH, 22MM, 3-POSITION, W/ (2)N.O. CONTACTS



① MOTOR CONTROLLER IS SUITABLE FOR USE AS SERVICE EQUIPMENT.
IF MOTOR CONTROLLER IS GOING TO BE USED AS SERVICE EQUIPMENT,
INSTALL "SERVICE DISCONNECT" LEGEND AS SHOWN.
"SERVICE DISCONNECT" IS SHIPPED LOOSE WITH MOTOR CONTROLLER.



