



Full Voltage Starter Check List

Information to obtain from the customer.

Motor Info:

Type of motor (pick one): Induction, Synchronous, Wound Rotor.

Horse Power _____ H.P.

Full Load Amps _____ Amps

Line Voltage _____ Volts

Phase: 3 phase or Single phase

Application:

Non reversing

Reversing

Wye Delta, Open transition, closed transition

Part Winding

Disconnect type

Non combination: No disconnect

Combination, type of disconnect required, circuit breaker, non fused switch, fusible switch

Control options required:

Start Stop push buttons

Hand off Auto

Local Off Remote

Door Mounted Reset

Run Pilot

Fault Pilot

Control power transformer

Enclosure Type

Open type, NEMA 1, 12, 4, 4X, 7, 9

Sizing the overload

1.) Multiply motor full load amps X 1.15 for total amps.

2.) Size overload range so the calculated amps is close to the mid range of the overload.

Tip:

Size the contactor after you size the overload to ensure a properly sized starter

When possible please provide motor horsepower and full load amps.